

## **Tri-Annual Business Inspection**

---

- Fire detection, alarm and extinguishing systems shall be inspected and tested **annually** in accordance with the International Fire Code and applicable National Fire Protection Association Standards.
- Commercial cooking fire-extinguishing systems shall be serviced at least every **6 months** and after activation of the system.



**Inspection of fire detection, alarm and extinguishing systems shall be by qualified individuals, and a certificate of inspection shall be forwarded to the inspector upon completion.**